

From: Don Rector
Sent: Monday, May 05, 2008 11:53 AM
To: 'David Selhorst'
Subject: RE: Owens Corning JRS Study
Attachments: ocwater

Attached you will find the letter in reference to water. I will drop that in the mail to Mr. Habig.

Donald S. Rector, P.E.
General Manager
Southwest Licking Community Water and Sewer District
P.O. Box 215
Etna, Oh 43018
740-927-0110 x110
740-927-4700 fax
www.swlcws.com

From: David Selhorst [mailto:SelhorstD@poggemeyer.com]
Sent: Friday, May 02, 2008 10:45 AM
To: Don Rector
Subject: RE: Owens Corning JRS Study

This sounds great. Can you generate a letter to Mr. Habig for water service similar to the one you did for the sanitary?
Thanks again!
-David

From: Don Rector [mailto:drector@swlcws.com]
Sent: Friday, May 02, 2008 10:41 AM
To: David Selhorst
Subject: RE: Owens Corning JRS Study

Great. Yes. Your information makes sense. Our overflow elevation is 1300.00 so the on the ground pressure at Owens would be 87 psi. It should be around 55 psi with Owens existing tank. The option would be floating off our tank for increased pressure or still use the onsite tank and installing a pressure reducing valve (altitude valve) to control the flow into the Owens tank. (make sense?). Of course the cost to run the line to the site may be around 400,000 depending on the size and distance and our tap fee would be based on the size of domestic and fire service line needed. Just for the fun of it an 8" is \$327,600 (\$285,390+\$42,210) so that would be the top end, with such a large site that is probably realistic. Our water rates are \$4.09 per 1000 gallons up to 40,000 gallons per month and 5.35 per 1000 for each thousand thereafter for the month.

Donald S. Rector, P.E.
General Manager
Southwest Licking Community Water and Sewer District
P.O. Box 215
Etna, Oh 43018
740-927-0410 x110
740-927-4700 fax
www.swlcws.com
